



Minutes

Regular Meeting

5:00 pm, September 10, 2020

Chairman Charles Hegler called the meeting to order with Commissioner Leonard Bowick, Commissioner George Yeldell, Superintendent James Robinson, Chief Water Plant Operator Troy Caparro and Office Manager Cheryl Daniels present.

On a motion by Commissioner Leonard Bowick, seconded by Commissioner George Yeldell, the Commissioners approved the August 2020 Regular Meeting Minutes and the August 2020 Accounts Payable.

Safety Committee Update:

Safety Training for the month of September will be Blood Borne Pathogen.

Cheryl Daniels ~ Office Manager:

The office has been short-staffed the last couple of weeks due to illness. There is no financial report this month – it will be submitted next month. Overall, operations are running smoothly in the office.

James Robinson ~ Superintendent:

JR stated that safety training for the month of September will be Blood Borne Pathogen. Overall, operations are running smoothly.

Glenn Hill ~ Chief Waste Water Operator:

Mr. Hegler presented Glenn's report:

The spare aerator was put in digester and the bad one was sent to Darby Electric for repair. All by 3 rights-of-way have been cut. A new weed eater has been purchased. Overall, operations are running smoothly.

Troy Caparro ~ Water Treatment Plant:

The lake level as of September 9 was 329.38 feet. The raw water intake level has been changed in the reservoir to reduce manganese intake levels. They have acquired permanganate for manganese control. They are continuing to feed copper sulfate for algae control. The water tank on Highway 378 has been cleaned, test and is back in service. The tank at the operations center has been taken out of service for approximately two months for painting the inside and outside. The new logo will be painted on it also.

There being no further business, Mr. Hegler made motion to adjourn.

Respectfully Submitted,

Cheryl Daniels

Cheryl Daniels
Office Manager

